

*Case study:
The need for reserves in
the South African
electrical power system*

*Launch of REPLI
DTU Renewable Energy
Policy, Planning and
Integration Advice Group
May 11, 2017*

Outline



Case study:

- *The need for reserves in the South African electrical power system*

Outline:

- *Project*
- *Wind power development cases*
- *Approach*
- *Impact on needs for reserves*



REPLI - DTU Renewable Energy Policy, Planning and Integration Advice Group, www.repli.dtu.dk




Project



Reliability with renewable energy

- ***System Adequacy and Reserve Margin with Increasing Levels of Variable Generation***

Partners:

- *Ea Energy Analysis (DK)*
- *EOH Enerweb (SA)*
- **DTU**    *(DK)*
 - *The need for reserves in the South African electrical power system*

Grid operators (TSOs):

- *Energinet.dk (DK)*
- *ESKOM (SA) [end user]*

Funding:

- *Danish Support to RE development in SA*



REPLI - DTU Renewable Energy Policy, Planning and Integration Advice Group, www.repli.dtu.dk


Wind power development cases



Cases

- 2014 Reference (Past) case
- 2020 Planned development case.
- 2025 Future for grid development planning.


Case year	2014	2020	2025
Installed wind power capacity [MW]	460	3800	7400
Consumption [TWh/y]	231	356	404
Penetration [%]	0.5	2.9	4.9




Simulation approach – wind power fluctuations




CorWind software developed at DTU Wind Energy



Mesoscale
wind speeds



Add wind speed
fluctuations



Wind to power
(and smoothing)

Results - Impact on reserves



- Focus on impact on expensive automatic reserves
- ESKOM considers impact of **load ramp rates** on need for those reserves

[Ancillary Services Technical Requirements 2015/16 – 2019/20. Rev. 1 ESKOM 28-10-2014.]

- We used wind power simulations to assess impact of **residual load ramp rates**:
residual load
 $\text{= consumption load} - \text{wind generation}$
- With **present** South African wind penetration cases, the resulting **increase is very small**
- ESKOM will consider variable generation in future requirements

Variable	Season	2014	2020	2025
Consumption variations [MW]	Summer	400	550	700
	Winter	500	650	800
Wind variations [MW]	-	29	106	155
Wind penetration	-	0.5	2.9	4.9
Total variations [MW]	Summer	401	560	717
	Winter	501	659	815
Increase due to wind [%]	Summer	0.3	1.8	2.4
	Winter	0.2	1.4	1.9

Use in REPLI



- Weather dependent variable generation and consumption:
 - Wind power
 - Solar PV}: have power simulation tools
 - Hydro power
 - Heat and cooling
- }: have correlated weather data
- Uses of variable RES generation time series:
 - Energy system planning
 - Network development planning
 - Power system reliability – adequacy
 - Needs for reserves

